

OHA

Oregon

Health Authority

Water Quality Parameter Monitoring Form**Lead & Copper Rule Corrosion Control**

County: Marion

Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
6/1/2025	7.46	28	Y
6/2/2025	7.54	28	Y
6/3/2025	7.56	28	Y
6/4/2025	7.63	30	Y
6/5/2025	7.46	28	Y
6/6/2025	7.50	27	Y
6/7/2025	7.35	27	Y
6/8/2025	7.36	25	Y
6/9/2025	7.43	30	Y
6/10/2025	7.35	29	Y
6/11/2025	7.34	31	Y
6/12/2025	7.49	27	Y
6/13/2025	7.58	29	Y
6/14/2025	7.51	29	Y
6/15/2025	7.45	25	Y
6/16/2025	7.65	24	Y
6/17/2025	7.63	26	Y
6/18/2025	7.49	29	Y
6/19/2025	7.42	30	Y
6/20/2025	7.54	28	Y
6/21/2025	7.38	29	Y
6/22/2025	7.75	29	Y
6/23/2025	7.53	29	Y
6/24/2025	7.40	30	Y
6/25/2025	7.36	28	Y
6/26/2025	7.31	27	Y
6/27/2025	7.26	29	Y
6/28/2025	7.24	29	Y
6/29/2025	7.51	26	Y
6/30/2025	7.31	27	Y
(No=N=Excursion)			Total N's
			0

<< Have
minimums
been met
for the day?**ENTRY POINT****EP-A****PWS ID: 4100731****System name**

City of Salem Public Works

Entry Point

Aldersgate

Sampling Period

June 2025

Number of excursions during this monthnone(Count the number of days when any WQP was less
than the minimum required)**Total excursions during the previous 5 months**none

(over 9 excursions in six months is a violation.)

Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality
Parameters as set by State**

pH

7.2

Alkalinity

15**Print Name:**Dwayne Barnes**Signature:****Date:**July 3, 2025

Send to DWP within 10 days after end of sampling period

OHA-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405