

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
2/1/2026	7.48	28	Y
2/2/2026	7.46	29	Y
2/3/2026	7.52	29	Y
2/4/2026	7.42	28	Y
2/5/2026	7.55	27	Y
2/6/2026	7.52	26	Y
2/7/2026	7.44	27	Y
2/8/2026	7.43	27	Y
2/9/2026	7.46	27	Y
2/10/2026	7.38	26	Y
2/11/2026	7.48	26	Y
2/12/2026	7.50	25	Y
2/13/2026	7.46	26	Y
2/14/2026	7.42	27	Y
2/15/2026	7.43	27	Y
2/16/2026	7.44	27	Y
2/17/2026	7.53	26	Y
2/18/2026	7.55	27	Y
2/19/2026	7.47	26	Y
2/20/2026	7.53	26	Y
2/21/2026	7.48	25	Y
2/22/2026	7.75	30	Y
2/23/2026	7.65	30	Y
2/24/2026	7.62	26	Y
2/25/2026	7.40	26	Y
2/26/2026	7.35	26	Y
2/27/2026	7.46	25	Y
2/28/2026	7.48	27	Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

<b>ENTRY POINT</b>	
<b>EP-A</b>	
<b>PWS ID: 4100731</b>	
<b>System name</b>	City of Salem Public Works
<b>Entry Point</b>	Aldersgate
<b>Sampling Period</b>	February 2026

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
<b>Minimum Water Quality Parameters as set by State</b>	
pH	7.2
Alkalinity	15

**Print Name:** Dwayne Barnes

**Signature:** 

**Date:** 3/4/2026