

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
9/1/2022	ON	7.62	24.0	Y
9/2/2022	ON	7.62	24.0	Y
9/3/2022	ON	7.77	25.0	Y
9/4/2022	ON	7.72	23.0	Y
9/5/2022	ON	7.72	24.0	Y
9/6/2022	ON	7.56	24.0	Y
9/7/2022	ON	7.47	24.0	Y
9/8/2022	ON	7.56	24.0	Y
9/9/2022	ON	7.65	26.0	Y
9/10/2022	ON	7.72	24.0	Y
9/11/2022	ON	7.91	24.0	Y
9/12/2022	OFF@0610	7.49	24.0	Y
9/13/2022	OFF			
9/14/2022	OFF			
9/15/2022	OFF			
9/16/2022	ON @ 1100, OFF @ 1300	7.44	25.0	Y
9/17/2022	OFF			
9/18/2022	OFF			
9/19/2022	OFF			
9/20/2022	OFF			
9/21/2022	OFF			
9/22/2022	OFF			
9/23/2022	OFF			
9/24/2022	OFF			
9/25/2022	OFF			
9/26/2022	OFF			
9/27/2022	OFF			
9/28/2022	OFF			
9/29/2022	ON @1110	7.69	25.0	Y
9/30/2022	ON	7.59	31.0	Y
(No=N=Excursion) Total N's				0

ENTRY POINT
EP-B
PWS ID: 4100731
City of Salem Public Works
ASR Facility
September 2022

System name
Entry Point
Sampling Period

Number of excursions during this month none


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only
Minimum Water Quality Parameters as set by State
pH <u>7.4</u>
Alkalinity <u>20 mg/l</u>

Print Name Dwayne Barnes

Signature: 

Date: October 6, 2022

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405