

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
10/1/2023	OFF			
10/2/2023	ON	7.50	27.0	Y
10/3/2023	ON	7.46	26.0	Y
10/4/2023	ON	8.02	28.0	Y
10/5/2023	ON	7.43	27.0	Y
10/6/2023	ON	7.48	28.0	Y
10/7/2023	ON	7.52	28.0	Y
10/8/2023	ON	7.48	29.0	Y
10/9/2023	ON	7.52	29.0	Y
10/10/2023	ON	7.67	28.0	Y
10/11/2023	ON	7.49	27.0	Y
10/12/2023	ON	7.45	28.0	Y
10/13/2023	ON	7.56	27.0	Y
10/14/2023	ON	7.41	28.0	Y
10/15/2023	ON	7.70	29.0	Y
10/16/2023	ON	7.46	29.0	Y
10/17/2023	OFF			
10/18/2023	ON	7.24	28.0	Y
10/19/2023	OFF			
10/20/2023	OFF			
10/21/2023	OFF			
10/22/2023	OFF			
10/23/2023	OFF			
10/24/2023	OFF			
10/25/2023	OFF			
10/26/2023	OFF			
10/27/2023	OFF			
10/28/2023	OFF			
10/29/2023	OFF			
10/30/2023	OFF			
10/31/2023	OFF			
(No=N=Excursion)			Total N's	0

ENTRY POINT
EP-B
PWS ID: 4100731
City of Salem Public Works
ASR Facility
October 2023


System name
Entry Point
Sampling Period

Number of excursions during this month 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality Parameters as set by State	
pH	<input type="text" value="7.2"/>
Alkalinity	<input type="text" value="15 mg/l"/> 

Print Name: Dwayne Barnes

Signature: 

Date: November 7, 2023

Send to DHS within 10 days after end of sampling period