

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
11/1/2023	OFF			
11/2/2023	OFF			
11/3/2023	OFF			
11/4/2023	OFF			
11/5/2023	OFF			
11/6/2023	OFF			
11/7/2023	OFF			
11/8/2023	OFF			
11/9/2023	OFF			
11/10/2023	OFF			
11/11/2023	OFF			
11/12/2023	OFF			
11/13/2023	OFF			
11/14/2023	OFF			
11/15/2023	OFF			
11/16/2023	OFF			
11/17/2023	OFF			
11/18/2023	OFF			
11/19/2023	OFF			
11/20/2023	OFF			
11/21/2023	ON @0935, OFF @1127	7.50	31.0	Y
11/22/2023	OFF			
11/23/2023	OFF			
11/24/2023	OFF			
11/25/2023	OFF			
11/26/2023	OFF			
11/27/2023	OFF			
11/28/2023	OFF			
11/29/2023	OFF			
11/30/2023	OFF			
(No=N=Excursion) Total N's				0

ENTRY POINT
EP-B
PWS ID: 4100731
City of Salem Public Works
ASR Facility
November 2023

System name
Entry Point
Sampling Period

Number of excursions during this month 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality Parameters as set by State	
pH	7.2
Alkalinity	15 mg/l

Print Name: Dwayne Barnes

Signature: 

Date: December 7, 2023

Send to DHS within 10 days after end of sampling period