

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
3/1/2024	OFF			
3/2/2024	OFF			
3/3/2024	OFF			
3/4/2024	OFF			
3/5/2024	OFF			
3/6/2024	OFF			
3/7/2024	OFF			
3/8/2024	OFF			
3/9/2024	OFF			
3/10/2024	OFF			
3/11/2024	OFF			
3/12/2024	OFF			
3/13/2024	OFF			
3/14/2024	OFF			
3/15/2024	OFF			
3/16/2024	OFF			
3/17/2024	OFF			
3/18/2024	OFF			
3/19/2024	OFF			
3/20/2024	OFF			
3/21/2024	OFF			
3/22/2024	OFF			
3/23/2024	OFF			
3/24/2024	OFF			
3/25/2024	OFF			
3/26/2024	OFF			
3/27/2024	OFF			
3/28/2024	OFF			
3/29/2024	OFF			
3/30/2024	OFF			
3/31/2024	OFF			
(No=N=Excursion) Total N's				0

ENTRY POINT
EP-B
PWS ID: 4100731
City of Salem Public Works
ASR Facility
March 2024

System name
Entry Point
Sampling Period

Number of excursions during this month 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality Parameters as set by State	
pH	<u>7.2</u>
Alkalinity	<u>15 mg/l</u>

Print Name: Dwayne Barnes

Signature: 

Date: April 4, 2024

Send to DHS within 10 days after end of sampling period