

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
1/1/2025	Off			
1/2/2025	Off			
1/3/2025	Off			
1/4/2025	Off			
1/5/2025	Off			
1/6/2025	off			
1/7/2025	off			
1/8/2025	off			
1/9/2025	off			
1/10/2025	off			
1/11/2025	off			
1/12/2025	off			
1/13/2025	off			
1/14/2025	off			
1/15/2025	off			
1/16/2025	off			
1/17/2025	OFF			
1/18/2025	OFF			
1/19/2025	off			
1/20/2025	off			
1/21/2025	off			
1/22/2025	OFF			
1/23/2025	OFF			
1/24/2025	OFF			
1/25/2025	OFF			
1/26/2025	OFF			
1/27/2025	OFF			
1/28/2025	OFF			
1/29/2025	OFF			
1/30/2025	OFF			
1/31/2025	OFF			
(No=N=Excursion) Total N's				0

ENTRY POINT
EP-B
PWS ID: 4100731
City of Salem Public Works
ASR Facility
January 2025

System name	City of Salem Public Works
Entry Point	ASR Facility
Sampling Period	January 2025

Number of excursions during this month 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality Parameters as set by State	
pH	<u>7.2</u>
Alkalinity	<u>15 mg/l</u>

Print Name: Dwayne Barnes

Signature: 

Date: February 6, 2025

Send to DHS within 10 days after end of sampling period