

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
8/1/2025	Off			
8/2/2025	Off			
8/3/2025	Off			
8/4/2025	Off			
8/5/2025	Off			
8/6/2025	Off			
8/7/2025	Off			
8/8/2025	Off			
8/9/2025	Off			
8/10/2025	Off			
8/11/2025	Off			
8/12/2025	Off			
8/13/2025	Off			
8/14/2025	Off			
8/15/2025	Off			
8/16/2025	Off			
8/17/2025	Off			
8/18/2025	Off			
8/19/2025	Off			
8/20/2025	Off			
8/21/2025	Off			
8/22/2025	Off			
8/23/2025	Off			
8/24/2025	Off			
8/25/2025	Off			
8/26/2025	Off			
8/27/2025	Off			
8/28/2025	Off			
8/29/2025	Off			
8/30/2025	Off			
8/31/2025	Off			
(No=N=Excursion) Total N's				0

ENTRY POINT

EP-B

PWS ID: 4100731

City of Salem Public Works
ASR Facility
August 2025

System name
Entry Point
Sampling Period

Number of excursions during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation.
Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality
Parameters as set by State**

pH 7.2

Alkalinity 15 mg/l



Print Name: Dwayne Barnes
Signature: 
Date: September 4, 2025

Send to DHS within 10 days after end of sampling period