

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
12/1/2025	Off			
12/2/2025	Off			
12/3/2025	Off			
12/4/2025	Off			
12/5/2025	Off			
12/6/2025	Off			
12/7/2025	Off			
12/8/2025	Off			
12/9/2025	Off			
12/10/2025	Off			
12/11/2025	Off			
12/12/2025	Off			
12/13/2025	Off			
12/14/2025	Off			
12/15/2025	Off			
12/16/2025	Off			
12/17/2025	Off			
12/18/2025	Off			
12/19/2025	Off			
12/20/2025	Off			
12/21/2025	ON	7.36	32.0	Y
12/22/2025	ON	7.32	28.0	Y
12/23/2025	On	7.24	24.0	Y
12/24/2025	on	7.48	31.0	Y
12/25/2025	on	7.34	31.0	Y
12/26/2025	ON	7.31		Y
12/27/2025	On	7.34		Y
12/28/2025	On	7.15	25.0	N
12/29/2025	On	7.29	27.0	Y
12/30/2025	On	7.27	26.0	Y
12/31/2025	On	7.16	25.0	N
(No=N=Excursion) Total N's				0

ENTRY POINT	
EP-B	
PWS ID: 4100731	
System name	City of Salem Public Works
Entry Point	ASR Facility
Sampling Period	December 2025

System name	City of Salem Public Works
Entry Point	ASR Facility
Sampling Period	December 2025

Number of excursions during this month 2

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 2

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality Parameters as set by State	
pH	<input type="text" value="7.2"/>
Alkalinity	<input type="text" value="15 mg/l"/>

Print Name: Dwayne Barnes

Signature: 

Date: January 7, 2026

Alkalinity samples not collected. Cody Marrs communicated this to Chantal Wikstrom by email.

Send to DHS within 10 days after end of sampling period