

OHA

Oregon

Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

| Date | System Status | ASR pH | ASR Alkalinity | Have minimums been met for the day? |
|-----------|---------------|--------|----------------|-------------------------------------|
| | | SU | mg/L | Y/N |
| 1/1/2026 | On | 7.42 | 28.0 | Y |
| 1/2/2026 | On | 7.55 | 29.0 | Y |
| 1/3/2026 | On | 7.47 | 28.0 | Y |
| 1/4/2026 | On | 7.50 | 31.0 | Y |
| 1/5/2026 | On | 7.54 | 28.0 | Y |
| 1/6/2026 | On | 7.91 | 29.0 | Y |
| 1/7/2026 | On | 7.44 | 29.0 | Y |
| 1/8/2026 | On | 7.67 | 28.0 | Y |
| 1/9/2026 | On | 7.41 | 27.0 | Y |
| 1/10/2026 | On | 7.58 | 28.0 | Y |
| 1/11/2026 | On | 7.34 | 28.0 | Y |
| 1/12/2026 | On | 7.42 | 26.0 | Y |
| 1/13/2026 | On | 7.44 | 28.0 | Y |
| 1/14/2026 | On | 7.33 | 25.0 | Y |
| 1/15/2026 | On | 7.53 | 28.0 | Y |
| 1/16/2026 | On | 7.42 | 27.0 | Y |
| 1/17/2026 | On | 7.22 | 26.0 | Y |
| 1/18/2026 | On | 7.59 | 28.0 | Y |
| 1/19/2026 | On | 7.52 | 27.0 | Y |
| 1/20/2026 | On | 7.50 | 27.0 | Y |
| 1/21/2026 | On | 7.44 | 28.0 | Y |
| 1/22/2026 | On | 7.70 | 28.0 | Y |
| 1/23/2026 | On | 7.44 | 28.0 | Y |
| 1/24/2026 | on | 7.24 | 27.0 | Y |
| 1/25/2026 | On | 7.42 | 29.0 | Y |
| 1/26/2026 | On | 7.49 | 27.0 | Y |
| 1/27/2026 | On | 7.36 | 27.0 | Y |
| 1/28/2026 | On | 7.55 | 27.0 | Y |
| 1/29/2026 | On | 7.43 | 28.0 | Y |
| 1/30/2026 | Off | | | |
| 1/31/2026 | Off | | | |
| Total N's | | | | 0 |

(No=N=Excursion)

ENTRY POINT

EP-B

PWS ID: 4100731

System name

City of Salem Public Works

Entry Point

ASR Facility

Sampling Period

January 2026

Number of excursions during this month

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months

0

(over 9 excursions in six months is a violation.

Entry point and distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State

pH

Alkalinity

Print Name:

R. Cody Marrs

Signature:

R. Cody Marrs

Date:

2/5/26

Send to DHS within 10 days after end of sampling period