

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
3/1/2026	Off			
3/2/2026	OFF			
3/3/2026	OFF			
3/4/2026	OFF			
3/5/2026	off			
3/6/2026	off			
3/7/2026	off			
3/8/2026	off			
3/9/2026	Off			
3/10/2026	Off			
3/11/2026	Off			
3/12/2026	Off			
3/13/2026	Off			
3/14/2026	Off			
3/15/2026	Off			
3/16/2026	Off			
3/17/2026	Off			
3/18/2026	Off			
3/19/2026	OFF			
3/20/2026	OFF			
3/21/2026	OFF			
3/22/2026	OFF			
3/23/2026	ON	7.27	23.0	Y
3/24/2026	OFF			
3/25/2026	OFF			
3/26/2026	Off			
3/27/2026	Off			
3/28/2026	Off			
3/29/2026	Off			
3/30/2026	ON	7.86	25.0	Y
3/31/2026	ON	7.79	25.0	Y
(No=N=Excursion) Total N's				0

ENTRY POINT	
EP-B	
PWS ID: 4100731	
System name	City of Salem Public Works
Entry Point	ASR Facility
Sampling Period	March 2026

Number of excursions during this month 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality Parameters as set by State	
pH	<u>7.2</u>
Alkalinity	<u>15 mg/l</u>

Print Name: Dwayne Barnes

Signature: 

Date: April 6, 2026

Send to DHS within 10 days after end of sampling period