

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Marion

Agency: REGION 1

Date	Location	pH Grab SU	Alk mg/L	Y/N
6/1/2022	1727 Madrona	7.65	23	Y
6/1/2022	2740 Turner	7.47	28	Y
6/1/2022	4406 Campbell	7.51	26	Y
6/1/2022	1395 46th	7.72	25	Y
6/1/2022	4893 Regal	7.65	25	Y
6/1/2022	4448 San Francisco	7.72	24	Y
6/1/2022	1884 Lansing	7.57	24	Y
6/1/2022	3014 Edgewood	7.53	25	Y
6/1/2022	1330 Tandem	7.62	23	Y
6/1/2022	1615 Winter	7.59	24	Y
6/1/2022	242 Gardenia	8.10	26	Y
6/7/2022	6250 Clubhouse	7.72	25	N
6/7/2022	2081 Elmwood	7.70	24	Y
6/7/2022	4730 Liberty	7.76	24	Y
6/7/2022	1516 Berndt Hill	7.75	23	N
6/7/2022	2950 Crestmont	7.77	24	Y
6/7/2022	200 Alice	7.83	24	Y
6/7/2022	850 High	7.72	24	Y
6/7/2022	3485 Lake Vanessa	8.44	26	Y
6/7/2022	3091 Kurt	8.10	24	Y
6/7/2022	2422 Wembly	7.77	24	Y
6/8/2022	1314 Ruge	7.99	25	Y
6/8/2022	1395 Overlook	8.28	25	Y
6/8/2022	3265 Glen Creek	7.91	24	Y
6/8/2022	511 36th	7.87	24	Y
(No=N=Excursion)		0	0	

<< Have minimums been met?

DISTRIBUTION

PWS ID: 4100731

System name City of Salem Public Works

Sampling Period January 1, 2022 - June 30, 2022

Number of excursions during this sampling period: 0

(Count the number of days when any WQP was less than the minimum.)

Note: Entry point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sampling period.

For DHS use only

Minimum Water Quality Parameters as set by State

pH
Alk

Print Name: Dwayne Barnes
Signature: _____

Date: 6/30/2022

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 972393-0350

Phone (971-673-0405) Website: <http://healthoregon.org/dwp/>