

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Marion

Agency: REGION 1

Date	Location	pH Grab SU	Alk mg/L	Y/N
8/27/2025	1727 Madrona	7.69	26.0	Y
8/27/2025	2740 Turner	7.66	26.0	Y
8/27/2025	4406 Campbell	7.66	27.0	Y
8/27/2025	1395 46th	7.93	28.0	Y
8/27/2025	4893 Regal	7.70	27.0	Y
8/27/2025	1884 Lansing	7.65	26.0	Y
8/27/2025	850 High	7.66	27.0	Y
8/27/2025	1615 Winter	7.63	26.0	Y
8/27/2025	4448 San Francisco	7.77	26.0	Y
8/27/2025	1330 Tandem	7.77	26.0	Y
8/27/2025	3014 Edgewood	7.67	26.0	Y
8/28/2025	3485 Lake Vanessa	7.98	28.0	Y
8/28/2025	3091 Kurt	7.82	28.0	Y
8/28/2025	2422 Wembly	7.73	26.0	Y
8/28/2025	1395 Overlook	7.92	28.0	Y
8/28/2025	3265 Glen Creek	7.75	28.0	Y
8/28/2025	511 36th	7.83	29.0	Y
8/28/2025	1314 Ruge	7.80	27.0	Y
8/27/2025	242 Gardenia	7.98	28.0	Y
8/28/2025	6626 Doral	7.71	27.0	Y
8/28/2025	2081 Elmwood	7.69	28.0	Y
8/28/2025	4730 Liberty	7.63	27.0	Y
8/28/2025	1516 Berndt Hill	7.73	28.0	Y
8/28/2025	2950 Crestmont	7.70	27.0	Y
8/28/2025	200 Alice	7.71	26.0	Y
(No=N=Excursion)		0	0.0	

<< Have
minimums
been met?

DISTRIBUTION

PWS ID: 4100731

System name

City of Salem Public Works

Sampling Period

June 1, 2025 - September 30, 2025

Number of excursions during this sampling period:

0

(Count the number of days when any WQP was less than the minimum.)

Note: Entry point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sampling period.

For DHS use only

Minimum Water Quality Parameters as set by State

pH 7.2
Alk 20



Print Name: Dwayne Barnes

Signature:

Date: October 8, 2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 972393-0350

Phone (971-673-0405) Website: <http://healthoregon.org/dwp/>