

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
10/1/2021	7.60		Y
10/2/2021	7.60		Y
10/3/2021	7.60		Y
10/4/2021	7.50		Y
10/5/2021	7.50		Y
10/6/2021	7.50		Y
10/7/2021	7.50		Y
10/8/2021	7.50		Y
10/9/2021	7.50		Y
10/10/2021	7.50		Y
10/11/2021	7.60		Y
10/12/2021	7.50		Y
10/13/2021	7.50		Y
10/14/2021	7.50		Y
10/15/2021	7.60		Y
10/16/2021	7.60		Y
10/17/2021	7.60		Y
10/18/2021	7.40		Y
10/19/2021	7.40		Y
10/20/2021	7.60		Y
10/21/2021	7.50		Y
10/22/2021	7.40		Y
10/23/2021	7.50		Y
10/24/2021	7.30		Y
10/25/2021	7.40		Y
10/26/2021	7.50		Y
10/27/2021	7.60		Y
10/28/2021	7.60		Y
10/29/2021	7.50		Y
10/30/2021	7.50		Y
10/31/2021	7.60		Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

**ENTRY POINT**

**EP-A**

PWS ID: 4100731

**System name** City of Salem Public Works

**Entry Point** Aldersgate

**Sampling Period** October 2021

**Number of excursions during this month**           none          

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months**           none          

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

**Print Name:** Dwayne Barnes

**Signature:**

**Date:** 11/2/2021