

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
3/1/2022	7.40		Y
3/2/2022	7.50		Y
3/3/2022	7.50		Y
3/4/2022	7.60		Y
3/5/2022	7.40		Y
3/6/2022	7.40		Y
3/7/2022	7.60		Y
3/8/2022	7.50		Y
3/9/2022	7.50		Y
3/10/2022	7.50		Y
3/11/2022	7.50		Y
3/12/2022	7.70		Y
3/13/2022	7.50		Y
3/14/2022	7.70		Y
3/15/2022	7.70		Y
3/16/2022	7.50		Y
3/17/2022	7.60		Y
3/18/2022	7.60		Y
3/19/2022	7.50		Y
3/20/2022	7.60		Y
3/21/2022	7.60		Y
3/22/2022	7.70		Y
3/23/2022	7.70		Y
3/24/2022	7.50		Y
3/25/2022	7.60		Y
3/26/2022	7.50		Y
3/27/2022	7.50		Y
3/28/2022	7.40		Y
3/29/2022	7.40		Y
3/30/2022	7.60		Y
3/31/2022	7.50		Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

**ENTRY POINT**

**EP-A**

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** March 2022

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)


**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

**Print Name:** Dwayne Barnes  
**Signature:**   
**Date:** 4/7/2022