

**OHA**

Oregon

Health Authority

**Water Quality Parameter Monitoring Form**

**Lead & Copper Rule Corrosion Control**

County: Marion

Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
Date	SU	mg/L	
5/1/2022	7.50		Y
5/2/2022	7.50		Y
5/3/2022	7.40		Y
5/4/2022	7.50		Y
5/5/2022	7.60		Y
5/6/2022	7.40		Y
5/7/2022	7.40		Y
5/8/2022	7.40		Y
5/9/2022	7.40		Y
5/10/2022	7.40		Y
5/11/2022	7.50		Y
5/12/2022	7.50		Y
5/13/2022	7.50		Y
5/14/2022	7.50		Y
5/15/2022	7.50		Y
5/16/2022	7.60		Y
5/17/2022	7.60		Y
5/18/2022	7.70		Y
5/19/2022	7.70		Y
5/20/2022	7.60		Y
5/21/2022	7.70		Y
5/22/2022	7.60		Y
5/23/2022	7.60		Y
5/24/2022	7.40		Y
5/25/2022	7.40		Y
5/26/2022	7.60		Y
5/27/2022	7.50		Y
5/28/2022	7.40		Y
5/29/2022	7.40		Y
5/30/2022	7.40		Y
5/31/2022	7.40		Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

**ENTRY POINT**

**EP-A**

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** May 2022

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

**Print Name:** Dwayne Barnes

**Signature:** 

**Date:** June 9, 2022

Send to DWP within 10 days after end of sampling period

OHA-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405