**OHA**
Oregon
Health Authority

# Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

## ENTRY POINT

## EP-A

## PWS ID: 4100731

| | |
|---|---|
| **System name** | City of Salem Public Works |
| **Entry Point** | Aldersgate |
| **Sampling Period** | June 2022 |

| | pH @ Aldersgate | Alkalinity @ Aldersgate | Y/N |
|---|---|---|---|
| | EP-A | EP-A | |
| **Date** | **SU** | **mg/L** | |
| 6/1/2022 | 7.40 | | Y |
| 6/2/2022 | 7.40 | | Y |
| 6/3/2022 | 7.50 | | Y |
| 6/4/2022 | 7.50 | | Y |
| 6/5/2022 | 7.50 | | Y |
| 6/6/2022 | 7.50 | | Y |
| 6/7/2022 | 7.70 | | Y |
| 6/8/2022 | 7.70 | | Y |
| 6/9/2022 | 7.60 | | Y |
| 6/10/2022 | 7.60 | | Y |
| 6/11/2022 | 7.40 | | Y |
| 6/12/2022 | 7.50 | | Y |
| 6/13/2022 | 7.40 | | Y |
| 6/14/2022 | 7.30 | | Y |
| 6/15/2022 | 7.30 | | Y |
| 6/16/2022 | 7.40 | | Y |
| 6/17/2022 | 7.30 | | Y |
| 6/18/2022 | 7.50 | | Y |
| 6/19/2022 | 7.50 | | Y |
| 6/20/2022 | 7.40 | | Y |
| 6/21/2022 | 7.40 | | Y |
| 6/22/2022 | 7.50 | | Y |
| 6/23/2022 | 7.50 | | Y |
| 6/24/2022 | 7.60 | | Y |
| 6/25/2022 | 7.60 | | Y |
| 6/26/2022 | 7.50 | | Y |
| 6/27/2022 | 7.60 | | Y |
| 6/28/2022 | 7.30 | | Y |
| 6/29/2022 | 7.40 | | Y |
| 6/30/2022 | 7.40 | | Y |
| | | | |
| | | | |
| (No=N=Excursion) | | **Total N's** | 0 |

<< Have minimums been met for the day?

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation.
Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

**Print Name:** Dwayne Barnes

**Signature:**

**Date:** 7/1/2022

Send to DWP within 10 days after end of sampling period
OHA-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405