

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
7/1/2022	7.50		Y
7/2/2022	7.60		Y
7/3/2022	7.50		Y
7/4/2022	7.60		Y
7/5/2022	7.60		Y
7/6/2022	7.50		Y
7/7/2022	7.60		Y
7/8/2022	7.50		Y
7/9/2022	7.60		Y
7/10/2022	7.50		Y
7/11/2022	7.60		Y
7/12/2022	7.60		Y
7/13/2022	7.50		Y
7/14/2022	7.60		Y
7/15/2022	7.50		Y
7/16/2022	7.50		Y
7/17/2022	7.50		Y
7/18/2022	7.60		Y
7/19/2022	7.60		Y
7/20/2022	7.60		Y
7/21/2022	7.60		Y
7/22/2022	7.50		Y
7/23/2022	7.50		Y
7/24/2022	7.50		Y
7/25/2022	7.60		Y
7/26/2022	7.70		Y
7/27/2022	7.40		Y
7/28/2022	7.40		Y
7/29/2022	7.30		Y
7/30/2022	7.40		Y
7/31/2022	7.40		Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

**ENTRY POINT**

**EP-A**

PWS ID: 4100731

**System name** City of Salem Public Works

**Entry Point** Aldersgate

**Sampling Period** July 2022

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** none


(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

**Print Name:** Dwayne Barnes

**Signature:** 

**Date:** 8/4/2022