

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
8/1/2022			
8/2/2022	7.50		Y
8/3/2022	7.30		Y
8/4/2022	7.30		Y
8/5/2022	7.60		Y
8/6/2022	7.70		Y
8/7/2022	7.50		Y
8/8/2022	7.30		Y
8/9/2022	7.60		Y
8/10/2022	7.80		Y
8/11/2022	7.70		Y
8/12/2022	7.60		Y
8/13/2022	7.60		Y
8/14/2022	7.60		Y
8/15/2022	7.60		Y
8/16/2022	7.50		Y
8/17/2022	7.50		Y
8/18/2022	7.50		Y
8/19/2022	7.50		Y
8/20/2022	7.50		Y
8/21/2022	7.60		Y
8/22/2022	7.40		Y
8/23/2022	7.60		Y
8/24/2022	7.60		Y
8/25/2022	7.60		Y
8/26/2022	7.50		Y
8/27/2022	7.50		Y
8/28/2022	7.50		Y
8/29/2022	7.50		Y
8/30/2022	7.50		Y
8/31/2022	7.50		Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

### ENTRY POINT

EP-A

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** August 2022

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)


**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

**Print Name:** Dwayne Barnes  
**Signature:**   
**Date:** September 7, 2022