

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

	pH @ Aldersgate	Alkalinity @ Aldersgate	Y/N
	EP-A	EP-A	
Date	SU	mg/L	
1/1/2024	7.40	25.00	Y
1/2/2024	7.50	24.00	Y
1/3/2024	7.50	26.00	Y
1/4/2024	7.40	26.00	Y
1/5/2024	7.60	26.00	Y
1/6/2024	7.60	25.00	Y
1/7/2024	7.50	26.00	Y
1/8/2024	7.50	26.00	Y
1/9/2024	7.50	26.00	Y
1/10/2024	7.50	27.00	Y
1/11/2024	7.40	26.00	Y
1/12/2024	7.50	26.00	Y
1/13/2024	7.40	26.00	Y
1/14/2024	7.40	27.00	Y
1/15/2024	7.60	26.00	Y
1/16/2024	7.50	25.00	Y
1/17/2024	7.60	26.00	Y
1/18/2024	7.60	27.00	Y
1/19/2024	7.70	25.00	Y
1/20/2024	7.70	21.00	Y
1/21/2024	7.70	23.00	Y
1/22/2024	7.60	24.00	Y
1/23/2024	7.50	22.00	Y
1/24/2024	7.50	23.00	Y
1/25/2024	7.50	24.00	Y
1/26/2024	7.40	25.00	Y
1/27/2024	7.40	23.00	Y
1/28/2024	7.40	25.00	Y
1/29/2024	7.40	24.00	Y
1/30/2024	7.40	24.00	Y
1/31/2024	7.40	26.00	Y
(No=N=Excursion)	<b>Total N's</b>		0

<< Have minimums been met for the day?

### ENTRY POINT

EP-A

**PWS ID: 4100731**

**System name** City of Salem Public Works  
**Entry Point** Aldersgate  
**Sampling Period** January 2024

**Number of excursions during this month** none

(Count the number of days when any WQP was less than the minimum required)


**Total excursions during the previous 5 months** none

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH	7.2
Alkalinity	15

**Print Name:** Dwayne Barnes  
**Signature:**   
**Date:** February 5, 2024

Send to DWP within 10 days after end of sampling period  
 OHA-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405