

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
11/1/2022	ON	7.67	26.0	Y
11/2/2022	ON	7.47	28.0	Y
11/3/2022	ON	7.67	25.0	Y
11/4/2022	ON	7.65	24.0	Y
11/5/2022	ON	7.62	25.0	Y
11/6/2022	ON	7.50	26.0	Y
11/7/2022	ON	7.64	25.0	Y
11/8/2022	ON	7.60	22.0	Y
11/9/2022	ON	7.63	22.0	Y
11/10/2022	ON	7.46	25.0	Y
11/11/2022	ON	7.76	25.0	Y
11/12/2022	ON	7.60	26.0	Y
11/13/2022	ON	7.74	26.0	Y
11/14/2022	ON	7.59	26.0	Y
11/15/2022	ON	7.63	26.0	Y
11/16/2022	ON	7.58	25.0	Y
11/17/2022	ON	7.49	25.0	Y
11/18/2022	ON	7.56	25.0	Y
11/19/2022	ON	7.66	27.0	Y
11/20/2022	ON	7.63	28.0	Y
11/21/2022	ON	7.61	25.0	Y
11/22/2022	ON	7.57	26.0	Y
11/23/2022	ON	7.62	27.0	Y
11/24/2022	ON	7.57	25.0	Y
11/25/2022	ON	7.71	27.0	Y
11/26/2022	ON	7.73	27.0	Y
11/27/2022	ON	7.76	27.0	Y
11/28/2022	ON	7.80	29.0	Y
11/29/2022	ON	7.68	27.0	Y
11/30/2022	ON	7.68	26.0	Y
(No=N=Excursion) Total N's				0

<b>ENTRY POINT</b>
<b>EP-B</b>
<b>PWS ID: 4100731</b>
City of Salem Public Works
ASR Facility
November 2022

<b>System name</b>	City of Salem Public Works
<b>Entry Point</b>	ASR Facility
<b>Sampling Period</b>	November 2022

**Number of excursions during this month** 0


(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** 1

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only	
<b>Minimum Water Quality Parameters as set by State</b>	
pH	<u>7.4</u>
Alkalinity	<u>20 mg/l</u>

**Print Name:** Dwayne Barnes

**Signature:** 

**Date:** December 5, 2022

Send to DHS within 10 days after end of sampling period  
DHS-Drinking Water Program, PO Box 14350, Portland OR 97293-0350 Phone (971) 673-0405