

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?	
		SU	mg/L	Y/N	
8/1/2023	ON	7.46	25.0	Y	
8/2/2023	ON	7.44	25.0	Y	
8/3/2023	ON	7.53	25.0	Y	
8/4/2023	ON	7.44	26.0	Y	
8/5/2023	ON	7.43	26.0	Y	
8/6/2023	ON	7.38	27.0	Y	
8/7/2023	ON	7.42	27.0	Y	
8/8/2023	ON	7.42	27.0	Y	
8/9/2023	ON	7.53	26.0	Y	
8/10/2023	ON	7.53	26.0	Y	
8/11/2023	ON	7.42	26.0	Y	
8/12/2023	ON	7.41	26.0	Y	
8/13/2023	ON	7.42	27.0	Y	
8/14/2023	ON	7.36	29.0	Y	
8/15/2023	ON	7.31	28.0	Y	
8/16/2023	ON	7.44	27.0	Y	
8/17/2023	ON	7.50	27.0	Y	
8/18/2023	ON	7.49	27.0	Y	
8/19/2023	ON	7.48	26.0	Y	
8/20/2023	ON	7.38	27.0	Y	
8/21/2023	ON	7.43	26.0	Y	
8/22/2023	ON	7.37	26.0	Y	
8/23/2023	ON	7.47	26.0	Y	
8/24/2023	ON	7.46	25.0	Y	
8/25/2023	ON	7.40	25.0	Y	
8/26/2023	ON	7.35	26.0	Y	
8/27/2023	ON	7.42	27.0	Y	
8/28/2023	ON	8.12	29.0	Y	
8/29/2023	ON	7.60	26.0	Y	
8/30/2023	ON	7.30	28.0	Y	
8/31/2023	ON	7.39	26.0	Y	
(No=N=Excursion)				<b>Total N's</b>	0

**ENTRY POINT**

**EP-B**

**PWS ID: 4100731**

City of Salem Public Works  
ASR Facility  
August 2023

**System name** City of Salem Public Works  
**Entry Point** ASR Facility  
**Sampling Period** August 2023

**Number of excursions during this month** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months** 0


(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State**

pH 7.2

Alkalinity 20 mg/l

**Print Name:** Dwayne Barnes  
**Signature:**   
**Date:** September 8, 2023

Send to DHS within 10 days after end of sampling period