

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?
		SU	mg/L	Y/N
2/1/2024	OFF			
2/2/2024	OFF			
2/3/2024	OFF			
2/4/2024	OFF			
2/5/2024	OFF			
2/6/2024	OFF			
2/7/2024	OFF			
2/8/2024	OFF			
2/9/2024	OFF			
2/10/2024	OFF			
2/11/2024	OFF			
2/12/2024	OFF			
2/13/2024	OFF			
2/14/2024	OFF			
2/15/2024	OFF			
2/16/2024	OFF			
2/17/2024	OFF			
2/18/2024	OFF			
2/19/2024	OFF			
2/20/2024	OFF			
2/21/2024	OFF			
2/22/2024	OFF			
2/23/2024	OFF			
2/24/2024	OFF			
2/25/2024	OFF			
2/26/2024	OFF			
2/27/2024	ON	7.53	21.0	Y
2/28/2024	ON	7.70	21.0	Y
2/29/2024	OFF			
(No=N=Excursion)		Total N's		0

ENTRY POINT

EP-B

PWS ID: 4100731

City of Salem Public Works
ASR Facility
February 2024

System name	City of Salem Public Works
Entry Point	ASR Facility
Sampling Period	February 2024

Number of excursions during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State

pH 7.2

Alkalinity 15 mg/l

Print Name: Dwayne Barnes

Signature:

Date: March 5, 2024

Send to DHS within 10 days after end of sampling period