

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Marion Agency: REGION 1

Date	System Status	ASR pH	ASR Alkalinity	Have minimums been met for the day?	
		SU	mg/L	Y/N	
6/1/2024	OFF				
6/2/2024	OFF				
6/3/2024	OFF				
6/4/2024	OFF				
6/5/2024	OFF				
6/6/2024	OFF				
6/7/2024	OFF				
6/8/2024	OFF				
6/9/2024	OFF				
6/10/2024	OFF				
6/11/2024	ON	7.32	23.0	Y	
6/12/2024	ON	7.20	22.0	Y	
6/13/2024	ON	7.32	22.0	Y	
6/14/2024	ON	7.42	23.0	Y	
6/15/2024	ON	7.38	23.0	Y	
6/16/2024	ON	7.43	23.0	Y	
6/17/2024	ON	7.35	22.0	Y	
6/18/2024	ON	7.26	21.0	Y	
6/19/2024	ON	7.34	22.0	Y	
6/20/2024	ON	7.80	23.0	Y	
6/21/2024	ON	7.64	22.0	Y	
6/22/2024	ON	7.48	22.0	Y	
6/23/2024	ON	7.57	23.0	Y	
6/24/2024	ON	7.46	22.0	Y	
6/25/2024	ON	7.57	22.0	Y	
6/26/2024	ON	7.39	21.0	Y	
6/27/2024	ON	7.40	22.0	Y	
6/28/2024	ON	7.28	21.0	Y	
6/29/2024	ON	7.31	21.0	Y	
6/30/2024	ON	7.50	25.0	Y	
(No=N=Excursion)				Total N's	0

ENTRY POINT
EP-B
PWS ID: 4100731
City of Salem Public Works
ASR Facility
June 2024

System name
Entry Point
Sampling Period

Number of excursions during this month 0

(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months 0

(over 9 excursions in six months is a violation. Entry point and distribution excursions are cumulative)


For DHS use only

Minimum Water Quality Parameters as set by State

pH

Alkalinity 

Print Name: Dwayne Barnes

Signature: 

Date: July 8, 2024

Send to DHS within 10 days after end of sampling period