

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Marion

Agency: REGION 1

Date	Location	pH Grab	Alk	Y/N
		SU	mg/L	
8/21/2023	1727 Madrona	7.58	27.0	Y
8/21/2023	2740 Turner	7.50	27.0	Y
8/21/2023	4406 Campbell	7.60	27.0	Y
8/21/2023	1395 46th	7.70	26.0	Y
8/21/2023	4893 Regal	7.60	28.0	Y
8/21/2023	1884 Lansing	7.59	27.0	Y
8/21/2023	850 High	7.59	27.0	Y
8/21/2023	1615 Winter	7.58	26.0	Y
8/22/2023	4448 San Francisco	7.70	28.0	Y
8/22/2023	1330 Tandem	7.57	27.0	Y
8/22/2023	3014 Edgewood	7.62	27.0	Y
8/22/2023	3485 Lake Vanessa	7.74	28.0	Y
8/22/2023	3091 Kurt	7.72	27.0	Y
8/22/2023	2422 Wembly	7.62	27.0	Y
8/22/2023	1395 Overlook	7.72	28.0	Y
8/22/2023	3265 Glen Creek	7.69	27.0	Y
8/22/2023	511 36th	7.72	28.0	Y
8/22/2023	1314 Ruge	7.73	30.0	Y
8/22/2023	242 Gardenia	8.04	29.0	Y
8/23/2023	6626 Doral	7.66	28.0	Y
8/23/2023	2081 Elmwood	7.42	26.0	Y
8/23/2023	4730 Liberty	7.52	27.0	Y
8/23/2023	1516 Berndt Hill	7.40	26.0	Y
8/23/2023	2950 Crestmont	7.60	28.0	Y
8/23/2023	200 Alice	7.53	27.0	Y
(No=N=Excursion)		0	0.0	

<< Have minimums been met?

DISTRIBUTION

System name	PWS ID: 4100731 City of Salem Public Works
Sampling Period	June 1, 2023 - September 30, 2023

Number of excursions during this sampling period: 0

(Count the number of days when any WQP was less than the minimum.)

Note: Entry point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sampling period.

For DHS use only

Minimum Water Quality Parameters as set by State

pH	7.2
Alk	20

Print Name: Dwayne Barnes
Signature: _____

Date: October 9, 2023

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 972393-0350
 Phone (971-673-0405) Website: <http://healthoregon.org/dwp/>