

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
5		7.9				Y
16		8.0				Y
29		8.2				Y
(N = No = Excursion) Total N's						0

<Has sample met the minimums? **ENTRY POINT**

PWS ID: 41 0 0 7 5 5

System Name: Illahe Golf Club

Sample Period: April 2024

Sample Frequency: Every 2 weeks

Entry Point Samples required: **2**

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by


pH 7.0

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: JJ Olson

Signature: 

Date: 05/09/2024