

## Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
7		7.54				Y
16		7.73				Y
26		7.93				Y
(N = No = Excursion)      Total N's						0

<Has sample met the minimums?      **ENTRY POINT**

PWS ID: 41 0 0 7 5 5

System Name: Illahe Golf Club

Sample Period: SEPT 2024

Sample Frequency: Every 2 weeks

Entry Point Samples required: **2**

**Number of excursions during this Sample Period = 0**

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**


pH 7.0

Alk   *(Alkalinity)*

PO4   *(Orthophosphate)*

Other (\_\_\_\_\_)

**Print Name:** JJ Olson

**Signature:** 

**Date:** 10/09/2024