

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	y/N
1	7.76 7.76				Y
2	7.78 7.78				Y
3	7.71				Y
4	7.70				Y
5	7.73				Y
6	7.69				Y
7	7.74				Y
8	7.72				Y
9	7.77				Y
10	7.70				Y
11	7.71				N
12	7.15				Y
13	7.21				Y
14	7.20				Y
15	7.14				Y
16	7.18				Y
17	7.12				Y
18	7.32				N
19	7.33				N
20	7.11				Y
21	7.04				Y
22	7.15				N
23	7.10				N
24	7.02				Y
25	7.18				N
26	7.13				N
27	7.19				N
28	7.15				N
29	7.18				Y
30	7.03				N
31	7.06				N

<<Have minimums been met for this day?

ENTRY POINT

00783

SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: August 2021
Month/Year

Number of excursions" during this month: 0
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____ (_____)

Print Name: David Simmons
Signature: [Signature]
Date: 9/2/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0