

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	'y'/N
1	7.21				Y
2	7.19				Y
3	7.22				Y
4	7.24				Y
5	7.26				Y
6	7.24				Y
7	7.26				Y
8	7.22				Y
9	7.27				Y
10	7.25				Y
11	7.28				Y
12	7.26				Y
13	7.29				Y
14	7.19				Y
15	7.22				Y
16	7.31				Y
17	7.35				Y
18	7.33				Y
19	7.37				Y
20	7.21				Y
21	7.23				Y
22	7.26				Y
23	7.29				Y
24	7.26				Y
25	7.25				Y
26	7.31				Y
27	7.29				Y
28	7.28				Y
29	7.24				Y
30	7.23				Y
31	7.25				Y

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: January 2022
Month/Year

Number of excursions" during this month: 0
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____ (_____)

Print Name: David Simmons
Signature: [Signature]
Date: 1/31/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0