



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	y'/N
1	7.26				Y
2	7.24				Y
3	7.21				Y
4	7.19				Y
5	7.23				Y
6	7.21				Y
7	7.24				Y
8	7.26				Y
9	7.23				Y
10	7.25				Y
11	7.26				Y
12	7.24				Y
13	7.28				Y
14	7.24				Y
15	7.26				Y
16	7.29				Y
17	7.21				Y
18	7.25				Y
19	7.28				Y
20	7.29				Y
21	7.26				Y
22	7.24				Y
23	7.23				Y
24	7.25				Y
25	7.21				Y
26	7.23				Y
27	7.31				Y
28	7.35				Y
29					
30					
31					

<<Have minimums been met for

this day?

SWS ID' 41

ENTRY POINT

00783

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: February 2022
Month/Year

Number of excursions" during this month: 0
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH	<u>7.0</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: David Simmons

Signature: [Signature]

Date: 2/28/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0