

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	'y'/N
1	7.31				Y
2	7.30				Y
3	7.38				Y
4	7.48				Y
5	7.39				Y
6	7.37				X
7	7.41				Y
8	7.43				Y
9	7.37				Y
10	7.35				Y
11	7.39				Y
12	7.41				Y
13	7.35				Y
14	7.39				Y
15	7.36				Y
16	7.28				Y
17	7.37				Y
18	7.31				Y
19	7.39				Y
20	7.41				Y
21	7.37				Y
22	7.35				Y
23	7.37				Y
24	7.35				Y
25	7.39				Y
26	7.26				Y
27	7.37				Y
28	7.36				Y
29	7.29				Y
30	7.26				Y
31					

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: April 2022
 Month/Year

Number of excursions" during this month: 0
 (Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 2
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
 Alk _____ (Alkalinity)
 PO4 _____ (Orthophosphate)
 Other _____ (_____)

Print Name: David Simmons

Signature: [Signature]

Date: 5/1/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's: 0