

Day	pH	Alk	Phos	Other	y'/N
1	7.04				Y
2	7.27				Y
3	7.21				Y
4	7.25				Y
5	7.19				Y
6	7.22				Y
7	7.17				Y
8	7.23				Y
9	7.25				Y
10	7.27				Y
11	7.29				Y
12	7.21				Y
13	7.40				Y
14	7.36				Y
15	7.39				Y
16	7.42				Y
17	7.45				Y
18	7.34				Y
19	7.16				Y
20	7.23				Y
21	7.24				Y
22	7.28				Y
23	7.56				Y
24	7.41				Y
25	7.34				Y
26	8.37				Y
27	8.31				Y
28	7.90				Y
29	7.71				Y
30	8.03				Y
31	8.11				Y

<<Have minimums been met for this day?

ENTRY POINT

00783

SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: May 2022
Month/Year

Number of excursions" during this month: 0
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____ (_____)

Print Name: David Simmons

Signature: [Signature]

Date: 6/2/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0