

Day	pH	Alk	Phos	Other	y'/N
1	7.49				
2	7.51				
3	7.12				
4	7.17				
5	7.26				
6	7.24				
7	7.21				
8	7.26				
9	7.27				
10	7.28				
11	7.26				
12	7.24				
13	7.26				
14	7.27				
15	7.28				
16	7.24				
17	7.26				
18	7.27				
19	7.23				
20	7.27				
21	7.28				
22	7.23				
23	7.21				
24	7.19				
25	7.24				
26	7.25				
27	7.25				
28	7.31				
29	7.40				
30	7.43				
31	7.41				

<<Have minimums been met for

ENTRY POINT

00783

this day?

SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: July 2022

Month/Year

Number of excursions" during this month: 2
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____ (_____)

Print Name: Dop Lovas

Signature: [Signature]

Date: 08/01/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's