

Day	pH	Alk	Phos	Other	y'/N
1	7.44				
2	7.37				
3	7.44				
4	7.32				
5	7.41				
6	7.42				
7	7.52				
8	7.52				
9	7.54				
10	7.49				
11	7.52				
12	7.59				
13	7.54				
14	7.51				
15	7.53				
16	7.50				
17	8.12				
18	7.52				
19	7.49				
20	7.46				
21	8.10				
22	7.91				
23	7.49				
24	7.30				
25	7.40				
26	7.36				
27					
28	7.34				
29	7.33				
30	7.34				
31	7.53				

<<Have minimums been met for

this day?

SWS ID' 41

ENTRY POINT

00783

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: AUGUST / 2022
Month/Year

Number of excursions" during this month: 2
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: David Simmons

Signature: [Signature]

Date: 9/1/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's