

Day	pH	Alk	Phos	Other	y/N
1	8.31				Y
2	8.44				Y
3	7.31				Y
4	7.37				Y
5	7.32				Y
6	7.46				Y
7	7.44				Y
8	7.36				Y
9	7.41				Y
10	7.39				Y
11	7.42				Y
12	7.38				Y
13	7.43				Y
14	7.39				Y
15	7.42				Y
16	7.37				Y
17	7.41				Y
18	7.36				Y
19	7.34				Y
20	7.62				Y
21	7.47				Y
22	7.41				Y
23	7.98				Y
24	7.44				Y
25	7.47				Y
26	7.41				Y
27	7.44				Y
28	7.41				Y
29	7.45				Y
30	7.39				Y
31	7.42				Y

<<Have minimums been met for

**ENTRY POINT**

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: October 2022  
 Month/Year

Number of excursions" during this month: 0  
 (Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 2  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0  
 Alk \_\_\_\_\_ (Alkalinity)  
 PO4 \_\_\_\_\_ (Orthophosphate)  
 Other \_\_\_\_\_ (\_\_\_\_\_)

Print Name: David Simmons

Signature: [Signature]

Date: 11/1/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0