



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	y/N
1	7.41				Y
2	7.38				Y
3	7.34				Y
4	7.36				Y
5	7.40				Y
6	7.42				Y
7	7.45				Y
8	7.41				Y
9	7.36				Y
10	7.34				Y
11	7.38				Y
12	7.35				Y
13	7.31				Y
14	7.34				Y
15	7.42				Y
16	7.51				Y
17	7.41				Y
18	7.38				Y
19	7.45				Y
20	7.41				Y
21	7.44				Y
22	7.48				Y
23	7.46				Y
24	7.44				Y
25	7.41				Y
26	7.38				Y
27	7.35				Y
28	7.31				Y
29	7.35				Y
30	7.33				Y
31					

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: November 2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only—

Minimum Water Quality Parameters as set by

pH 7.0  
 Alk \_\_\_\_\_ (Alkalinity)  
 PO4 \_\_\_\_\_ (Orthophosphate)  
 Other \_\_\_\_\_

Print Name: David S. Summers  
 Signature: [Signature]  
 Date: 12/2/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>