



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	y'/N
1	7.43				Y
2	7.39				Y
3	7.36				Y
4	7.41				Y
5	7.62				Y
6	7.59				Y
7	7.56				Y
8	7.31				Y
9	7.33				Y
10	7.51				Y
11	7.49				Y
12	7.47				Y
13	7.46				Y
14	7.36				Y
15	7.39				Y
16	7.20				Y
17	7.23				Y
18	7.21				Y
19	7.26				Y
20	7.20				Y
21	7.15				Y
22	7.31				Y
23	7.41				Y
24	7.40				Y
25	7.29				Y
26	7.36				Y
27	7.38				Y
28	7.12				Y
29	7.33				Y
30	7.42				Y
31	7.39				Y

<<Have minimums been met for

ENTRY POINT

00783

this day?

SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: December 2022
 Month/Year

Number of excursions" during this month: 0
 (Count the number of days when any WQP'was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0

Alk _____ (Alkalinity)

PO4 _____ (Orthophosphate)

Other _____ (_____)

Print Name: David Simmons

Signature: [Signature]

Date: 11/1/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0