



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other'y'/N
1	7.08			
2	7.10			
3	7.18			ALK 32mg/L
4	7.28			
5	7.24			
6	7.30			
7	7.31			
8	7.45			
9	7.41			
10	7.39			
11	7.34			
12	7.46			
13	7.42			
14	7.48			
15	7.53			
16	7.61			
17	7.57			
18	7.42			
19	7.31			
20	7.27			
21	7.31			
22	7.27			
23	7.31			
24	7.34			
25	7.36			
26	7.52			
27	7.54			
28	7.31			ALK 95mg/L
29				
30				
31				

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: FEBRUARY 2023
Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only—

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: DON LOYAS

Signature: [Signature]

Date: 2/20/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's