

Day	pH	Alk	Phos	Other	'y'/N
1	7.61				
2	7.74				
3	7.76				
4	7.81				
5	7.87				
6	7.68	68mg/L			
7	7.84				
8	7.70				
9	7.76				
10	7.74				
11	7.76				
12	7.52	81mg/L			
13	7.49				
14	7.22				
15	7.26				
16	7.48				
17	7.45	72mg/L			
18	7.51				
19	7.49				
20	7.41				
21	7.37				
22	7.87				
23	7.89				
24	7.80				
25	7.70	78mg/L			
26	7.78				
27	8.04				
28	7.74				
29	7.75				
30	7.85				
31					

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: _____

Sept 23 Month/Year

Number of excursions" during this month: 4
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by	
pH	<u>7.0</u>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: DON LOVAS

Signature: _____

Date: 10/1/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's