

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other 'y' / N
1	7.81			
2	7.72			
3	7.91	80mg/L		
4	7.75			
5	7.69			
6	7.96			
7	7.85			
8	7.78			
9	7.83			
10	7.53	90mg/L		
11	7.58			
12	7.72			
13	7.43			
14	7.41			
15	7.48			
16	7.81			
17	7.70	90mg/L		
18	7.98			
19	7.81			
20	7.78			
21	7.47			
22	7.32			
23	7.54			
24	7.85	80mg/L		
25	7.83			
26	7.77			
27	7.84			
28	7.80			
29	7.73			
30	7.84			
31	7.68			

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: OCT / 2023 Month/Year

Number of excursions" during this month: 2
 (Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by	
pH	<u>7.0</u>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: DON LOVAS

Signature: [Signature]

Date: 10/31/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's