

Day	pH	Alk	Phos	Other'y'/N
1	7.68			
2	7.70	68 mg/L		
3	7.55			
4	7.78			
5	7.56			
6	7.73			
7	7.41			
8	7.75			
9	7.79	80 mg/L		
10	7.88			
11	7.87			
12	7.73			
13	7.81			
14	7.89			
15	7.82	90 mg/L		
16	7.78			
17	7.75			
18	7.82			
19	7.80			
20	7.86	100 mg/L		
21	7.90			
22	7.95			
23	7.93			
24	7.89			
25	7.92			
26	7.38			
27	7.40	80 mg/L		
28	7.34			
29	7.67			
30	7.82			
31	7.81			

<<Have  
minimums  
been met for

**ENTRY POINT**

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: Nov 23 Month/Year

Number of excursions" during this month: 8  
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 9  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality  
Parameters as set by

pH 7.0  
Alk \_\_\_\_\_ (Alkalinity)  
PO4 \_\_\_\_\_ (Orthophosphate)  
Other \_\_\_\_\_ (\_\_\_\_\_)

Print Name: Don Louns

Signature: \_\_\_\_\_

Date: 12/1/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's