

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.91				Y
2	7.81	90mg/L			Y
3	7.86				Y
4	7.83				Y
5	7.99				Y
6	7.99				Y
7	8.08				Y
8	8.01				Y
9	7.96				Y
10	7.98	140mg/L			Y
11	7.89				Y
12	8.03				Y
13	7.99				Y
14	8.04				Y
15	8.06				Y
16	7.99				Y
17	7.91	120mg/L			Y
18	7.94				Y
19	7.84				Y
20	7.86				Y
21	7.41				Y
22	7.12				Y
23	7.84	80mg/L			Y
24	7.86				Y
25	7.91				Y
26	7.97				Y
27	8.08				Y
28	8.06				Y
29	8.06	80mg/L			Y
30	8.06				Y
31	7.83				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00703

System Name: ORCHARD HEIGHTS WATER ASSOCIATION

Entry Point: A

Sample Period: DECEMBER 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.00
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: DON LOVAS

Signature: *[Signature]*

Date: 1/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0