

Day	pH	Alk	Phos	Other	Y/N
1	7.72	40mg/L			Y
2	7.89				Y
3	7.94				Y
4	7.85				Y
5	7.89				Y
6	7.74				Y
7	7.80				Y
8	7.98				Y
9	7.87	60mg/L			Y
10	7.92				Y
11	7.80				Y
12	7.87				Y
13	7.90				Y
14	7.84				Y
15	7.95				Y
16	8.21	40mg/L			Y
17	7.81				Y
18	7.70				Y
19	7.86				Y
20	7.91				Y
21	7.86				Y
22	7.93				Y
23	7.77	60mg/L			Y
24	7.89				Y
25	7.77				N
26	7.67				Y
27	7.68				Y
28	7.84				Y
29	7.90				Y
30	7.88				Y
31	7.92	40mg/L			Y

No Ready

unable to get sample

(No = N = Excursion) Total N's 1

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00783

System Name: ORCLAND HOUGHTON WATER ASSOCIATION

Entry Point: A

Sample Period: MARCH 2024
Month/Year

Number of excursions* during this month: 1
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.00

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: DON LOYAS

Signature: *[Signature]*

Date: 04/01/2024

Send to DWP within 10 days after end of sampling period