

Day	pH	Alk	Phos	Other	Y/N
1	7.81				Y
2	7.83				Y
3	7.98				Y
4	7.96				Y
5	7.86				Y
6	7.84	60mg/L			Y
7	7.78				Y
8	7.87				Y
9	7.91				Y
10	7.86				Y
11	7.72				Y
12	7.83				Y
13	7.87	40mg/L			Y
14	7.88				Y
15	8.01				Y
16	8.12				Y
17	7.49				Y
18	7.79				Y
19	7.85				Y
20	7.80	80mg/L			Y
21	7.68				Y
22	8.05				Y
23	7.68				Y
24	7.78				Y
25	7.92				Y
26	7.72	100mg/L			Y
27	7.84				Y
28	7.96				Y
29	8.07				Y
30	7.84				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: ORCHARD HEIGHTS WATER ASSN

Entry Point: A

Sample Period: APRIL 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: DAN LOYAS

Signature: [Signature]

Date: 5/01/2024

Send to DWP within 10 days after end of sampling period