

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.90				X
2	7.85				Y
3	7.91	100mg/L			Y
4	7.74				Y
5	7.83				Y
6	7.92				Y
7	7.61				Y
8	7.16				Y
9	7.65				Y
10	7.86	80mg/L			Y
11	7.91				Y
12	8.02				Y
13	8.13				Y
14	7.73				Y
15	7.85				Y
16	7.98				Y
17	7.84	70mg/L			Y
18	7.91				Y
19	7.80				Y
20	7.98				Y
21	7.69				Y
22	7.99				Y
23	7.92				Y
24	7.89	100mg/L			Y
25	7.91				Y
26	7.97				Y
27	7.98				Y
28	7.82				Y
29	7.89				Y
30	7.91				Y
31	7.99	80mg/L			Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 00783

System Name: ORCHARD HEIGHTS WATER ASSN.

Entry Point: A

Sample Period: MAY 2024  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**


pH 7.00

Alk    (Alkalinity)

PO4    (Orthophosphate)

Other    (\_\_\_\_\_)

Print Name: DON LOVAS

Signature: 

Date: MAY 1, 2024

Send to DWP within 10 days after end of sampling period