

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.86				Y
2	7.91				Y
3	7.78				Y
4	7.81				Y
5	7.99				Y
6	7.56	100mg/L			Y
7	7.86				Y
8	7.91				Y
9	7.86				Y
10	8.24				Y
11	7.68				Y
12	7.85				Y
13	7.90	80mg/L			Y
14	7.87				Y
15	7.91				Y
16	7.84				Y
17	7.66				Y
18	7.82				Y
19	7.84				Y
20	7.88	100mg/L			Y
21	7.65				Y
22	8.00				Y
23	8.14				Y
24	7.63				Y
25	7.71				Y
26	7.77				Y
27	7.83	80mg/L			Y
28	7.78				Y
29	7.94				Y
30	8.06				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: ORCHARD HEIGHTS WATER ASSN.

Entry Point: A

Sample Period: JUNE 2024
Month/Year

Number of excursions* during this month: 2
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: DON LOYAS

Signature: [Signature]

Date: 06/30/2024

Send to DWP within 10 days after end of sampling period