

Day	pH	Alk	Phos	Other	Y/N
1	7.62				Y
2	7.73	80mg/L			Y
3	7.66				Y
4	7.81				Y
5	7.85				Y
6	7.84				Y
7	7.92	100mg/L			Y
8	7.96				Y
9	7.92				Y
10	8.11				Y
11	8.02				Y
12	7.93				Y
13	7.84	80mg/L			Y
14	7.91				Y
15	7.96				Y
16	8.12				Y
17	8.02				Y
18	7.64				Y
19	7.89				Y
20	7.94	100mg/L			Y
21	8.09				Y
22	7.67				Y
23	8.03				Y
24	8.01				Y
25	7.96				Y
26	8.14				Y
27	7.84	120mg/L			Y
28	7.43				Y
29	7.82				Y
30	7.86				Y
31	7.98				Y

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41

00983

System Name: ORCHARD HEIGHTS WATER ASSN

Entry Point: A

Sample Period: JULY 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

#### Minimum Water Quality Parameters as set by

pH 7.00  
Alk \_\_\_\_\_ (Alkalinity)  
PO4 \_\_\_\_\_ (Orthophosphate)  
Other \_\_\_\_\_ (\_\_\_\_\_)

Print Name: DON LOVAS

Signature: \_\_\_\_\_

Date: 07/29/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0