

Day	pH	Alk	Phos	Other	Y/N
1	7.74				Y
2	7.63	100mg/L			Y
3	7.54				Y
4	8.08				Y
5	7.98				Y
6	7.88				X
7	7.90				Y
8	7.66				X
9	7.95	80mg/L			X
10	8.34				X
11	8.14				Y
12	7.73				Y
13	8.11				Y
14	7.57				Y
15	8.31				Y
16	7.98	100mg/L			Y
17	8.02				Y
18	7.94				Y
19	7.69				Y
20	7.59				Y
21	7.76				Y
22	8.15	80mg/L			Y
23	7.84				Y
24	7.65				Y
25	8.01				Y
26	8.24				Y
27	7.89				Y
28	8.12				Y
29	8.02				X
30	8.09				Y
31	7.98				Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: ORCHARD HEIGHTS

Entry Point: A

Sample Period: AUGUST, 2024
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.00"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: DON LOYAS

Signature:

Date: 08/30/2024

Send to DWP within 10 days after end of sampling period