

Day	pH	Alk	Phos	Other	Y/N
1	7.84				Y
2	7.94	80mg/L			Y
3	7.81				Y
4	7.79				Y
5	7.84				Y
6	7.93				Y
7	7.41				Y
8	7.58				Y
9	7.61	100mg/L			Y
10	7.77				Y
11	7.84				Y
12	8.09				Y
13	7.86				Y
14	7.95				Y
15	7.39				Y
16	7.69				Y
17	7.80	80mg/L			Y
18	8.12				Y
19	7.91				Y
20	8.01				Y
21	8.12				Y
22	8.20				Y
23	8.04	100mg/L			Y
24	8.02				Y
25	7.89				Y
26	8.12				Y
27	7.87				Y
28	8.08				Y
29	8.07	80mg/L			Y
30	7.91				Y
31	8.17				Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: ORCHARD HEIGHTS WATER ASSOCIATION

Entry Point: A

Sample Period: October 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.00"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: DON LOVINS

Signature: [Signature]

Date: 11/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's