

Day	pH	Alk	Phos	Other	Y/N
1	8.22				Y
2	7.96	80mg/L			Y
3	8.02				Y
4	7.98				Y
5	8.04				Y
6	8.07				Y
7	8.01				Y
8	7.85	100mg/L			Y
9	7.88				Y
10	8.15				Y
11	7.60				Y
12	8.06				Y
13	7.85				Y
14	7.86	80mg/L			Y
15	7.92				Y
16	7.88				Y
17	7.89				Y
18	7.78				Y
19	7.74				Y
20	8.09	100mg/L			Y
21	7.95				Y
22	7.93				Y
23	8.21				Y
24	7.57				Y
25	8.23				Y
26	8.13				Y
27	8.03				Y
28	7.90	100mg/L			Y
29	7.98				Y
30	8.04				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: OXFORD HEIGHTS WATER ASSOCIATION

Entry Point: A

Sample Period: NOV 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: DUN LINDAS
 Signature: [Signature]
 Date: 11/3

Send to DWP within 10 days after end of sampling period